



ALBUQUERQUE FIRE DEPARTMENT PREAPPROVED TENT FLOOR PLANS

EVENT _____	VENDOR NAME _____	FLOOR PLAN # _____
PRINTED NAME _____	SIGNATURE _____	Booth# _____

The signing of this document hereby acknowledges that all requirements indicated below will be adhered to in order for this document to be approved and permitted. The standards specified below are the minimal requirements which the applicant is not limited to. Additional Fire Codes may apply during initial inspection if unforeseeable circumstances arise.

FAILURE TO COMPLY: Deviating from the requirements listed below may result in legal action being taken against the violator by issuing criminal citations or by ordering the removal of the canopy until compliance is achieved.

Tent requirements:

- The canopy and any side walls shall meet one of the following flame retardant standards.
 - CPAI84, NFPA 701, California fire retardant standards
- Each tent shall have one no smoking sign conspicuously located
- Each tent shall be anchored to withstand the elements of weather and prevent collapse.
 - Stake each leg or attach 25Lbs. per leg
- The tent frame and membrane shall be free of combustible materials.
- The tent frame shall not be used to brace, hang, support any objects. Exception: tent membrane, fire extinguisher
- All display grids and display racks shall be noncombustible or flame treated, preferably constructed out of metal.

Pick one of the preapproved floor plans and mark your selection above.

